

Title	Carry out cathodic protection system monitoring in an energy and chemical plant		
Level	4	Credits	3

Purpose	People credited with this unit standard are able to: assess, select, and operate cathodic protection system monitoring equipment; locate, interpret, and use documentation and reporting procedures for cathodic protection systems; and calculate and report results of testing cathodic protection systems; in an energy and chemical plant.
----------------	--

Classification	Energy and Chemical Plant > Monitoring of Energy and Chemical Plant
-----------------------	---

Available grade	Achieved
------------------------	----------

Prerequisite	Unit 9575, <i>Describe the purpose and application of cathodic protection in an energy and chemical plant, or demonstrate equivalent knowledge and skills.</i>
---------------------	--

Guidance Information

- Legislation and standards relevant to this unit standard include but are not limited to:
 - Health and Safety at Work Act 2015;
 - Health and Safety at Work (Hazardous Substances) Regulations 2017 (HSWA);
 - Resource Management Act 1991;
 - Standards relating to cathodic protection issued by: National Association Corrosion Engineers (NACE), available at <http://www.nace.org>; Standards Australia, available at <http://www.saiglobal.com>; and any subsequent amendments.
- Definitions

Energy and chemical plant may be in – petrochemical, agri-nutrient, power generation, dairy processing, meat processing, and wood fibre manufacturing, or other plants that operate with a combination of high temperatures, pressures, steam and/or chemicals in gas, liquid or solid form.

Organisational requirements – documented policies and procedures. These may include: equipment manufacturers' procedures; plant procedures; suppliers' instructions; site signage; codes of practice; company health and safety plans; on site briefings; and supervisor's instructions. This includes all regulatory and legislative obligations that apply to the plant.

Plant – the operational unit, equipment, and/or workplace at which the person is working.

Primary data refers to first analysis results.

- 3 For the purposes of assessment:
- evidence for the practical components of this unit standard must be supplied from the workplace.
 - evidence for all outcomes must be presented in accordance with organisational requirements.

Outcomes and performance criteria

Outcome 1

Assess, select, and operate cathodic protection system monitoring equipment in an energy and chemical plant.

Performance criteria

- 1.1 Assess the integrity of the cathodic protection system to determine the need to use cathodic protection system monitoring equipment.
- 1.2 Select cathodic protection system monitoring equipment relevant to site conditions.
- 1.3 Operate cathodic protection system monitoring equipment safely to determine the extent of maintenance required.
- 1.4 Identify and minimise any potential hazards from incorrect application and operation of cathodic protection system monitoring equipment.

Range under protection, over protection.

Outcome 2

Locate, interpret, and use documentation and reporting procedures for cathodic protection systems in an energy and chemical plant.

Performance criteria

- 2.1 Locate and use specified documentation and standards for cathodic protection monitoring equipment.
- Range test certificates, certification, standards for safety, standards for in-service safety inspection and testing of equipment, identification tags, labels.
- 2.2 Locate and interpret general equipment documentation and information.
- Range manufacturer's information, equipment operating manuals, safety procedures, operating procedures, maintenance procedures.

- 2.3 Identify international cathodic protection standards and reporting criteria specific to the site.

Range international standards – BSI British, Standards Australia, NACE.

Outcome 3

Calculate and report results of testing cathodic protection systems in an energy and chemical plant.

Performance criteria

- 3.1 Make any corrections to primary data in accordance with authorised procedures.
- 3.2 Calculate results from primary data.
- 3.3 Investigate and report any deviations from the expected range of results.
- 3.4 Compile a report including calculated results, analysis, and conclusions.

Planned review date	31 December 2025
----------------------------	------------------

Status information and last date for assessment for superseded versions

Process	Version	Date	Last Date for Assessment
Registration	1	6 February 1997	31 December 2018
Revision	2	3 August 2000	31 December 2018
Review	3	24 January 2002	31 December 2018
Review	4	20 February 2009	31 December 2018
Rollover and Revision	5	20 April 2017	31 December 2022
Review	6	27 February 2020	N/A

Consent and Moderation Requirements (CMR) reference	0079
--	------

This CMR can be accessed at <http://www.nzqa.govt.nz/framework/search/index.do>.

Comments on this unit standard

Please contact the Primary Industry Training Organisation standards@primaryito.ac.nz if you wish to suggest changes to the content of this unit standard.