

<b>Title</b>	<b>Terminate live low voltage polymeric insulated power cables in the electricity supply industry</b>		
<b>Level</b>	<b>4</b>	<b>Credits</b>	<b>10</b>

<b>Purpose</b>	People credited with this unit standard are able to terminate live low voltage polymeric insulated power cables in the electricity supply industry.
----------------	---

<b>Classification</b>	Electricity Supply > Electricity Supply - Live Work
-----------------------	---

<b>Available grade</b>	Achieved
------------------------	----------

---

### Guidance Information

- 1 Evidence presented for assessment against this unit standard must be consistent with safe working practices and be in accordance with applicable legislative and industry requirements.
- 2 Legislation, regulations and/or industry standards relevant to this unit standard include but are not limited to the current version of the Health and Safety at Work Act 2015; Electricity Act 1992; Electricity (Safety) Regulations 2010; and any subsequent amendments and replacements; Electricity supply industry codes of practice and documented enterprise procedures, including *Safety Manual – Electricity Industry* (SM-EI) (2015) Wellington: Electricity Engineers' Association available at [www.eea.co.nz](http://www.eea.co.nz), and IEC 60900:2018 *Live working – Hand tools for use up to 1000 V AC and 1500 V DC*.
- 3 Definitions  
*Asset owner* refers to a participant who owns or operates assets used for generating or conveying electricity.  
*Low voltage* – voltages exceeding 50V AC but not exceeding 1000V AC.  
*Industry requirements* include all asset owner requirements; manufacturers' specifications; and enterprise requirements which may include the documented workplace policies, procedures, specifications, business, and quality management requirements relevant to the workplace in which assessment is carried out.
- 4 This unit standard excludes tough plastic sheath (TPS) type cables.

---

## Outcomes and performance criteria

### Outcome 1

Terminate live low voltage polymeric insulated power cables in the electricity supply industry.

Range evidence for three terminations is required.

### Performance criteria

1.1 Work site is prepared, and safe working zone is established.

Range scope of work, identification and testing of cables, permit requirements, tools and equipment.

1.2 Terminations are prepared.

Range cleaning, conductor preparation, stripping, earthing.

1.3 Conductors are terminated.

Range compression, mechanical.

1.4 Conductors are re-insulated.

Range may include but is not limited to – barrier, elastomer, heat shrink, tapes, resins;  
evidence of two is required.

1.5 Mechanical and environmental integrity and earth continuity are re-established.

1.6 Terminations are mounted in an enclosure.

Range below ground, above ground.

1.7 Cables are tested after termination.

Range includes but is not limited to – voltage, phase rotation.

1.8 Termination as built is recorded to asset owner standards.

Range includes but is not limited to – location, test results.

---

<b>Planned review date</b>	31 December 2025
----------------------------	------------------

**Status information and last date for assessment for superseded versions**

Process	Version	Date	Last Date for Assessment
Registration	1	22 October 2003	31 December 2016
Rollover and Revision	2	24 August 2007	31 December 2016
Review	3	16 April 2010	31 December 2016
Review	4	18 September 2014	31 December 2022
Review	5	27 February 2020	N/A

**Consent and Moderation Requirements (CMR) reference**

0120

This CMR can be accessed at <http://www.nzqa.govt.nz/framework/search/index.do>.

**Comments on this unit standard**

Please contact Connexis – Infrastructure Industry Training Organisation [qualifications@connexis.org.nz](mailto:qualifications@connexis.org.nz) if you wish to suggest changes to the content of this unit standard.