Title	Inspect fixed fire protection systems for compliance		
Level	5	Credits	40

Purpose	This unit standard is for fixed fire protection systems technicians who wish to become inspection personnel required to inspect fixed fire protection systems for compliance with standard NZS 4541:2020 and/or other relevant standards listed in the references.	
	People credited with this unit standard are able to: prepare for inspections for fixed fire protection systems compliance; inspect fixed fire protection systems for compliance; complete inspection documentation for compliance of fixed fire protection systems.	

Classification	Mechanical Engineering > Fixed Fire Protection Systems
Available grade	Achieved

Guidance Information

1 Legislation, regulations and/or industry standards relevant to this unit standard include but are not limited to the:

Building Act 2004,

Building (Forms) Regulations 2004,

Ministry of Business, Innovation and Employment (MBIE) Acceptable Solutions (AS) and Verification Methods (VM),

MBIE New Zealand Building Code Handbook,

AS 4587:2020, Water mist fire protection systems - System design, installation, and commissioning,

AS ISO 14520.1-2023, Gaseous fire-extinguishing systems - Physical properties and system design – Part 1: General requirements

AS ISO 14520.10-2019, Gaseous fire-extinguishing systems - Physical properties and system design - HFC 23 extinguishant

AS ISO 14520.14-2015, Gaseous fire-extinguishing systems - Physical properties and system design - IG-55 extinguishant

AS ISO 14520.15-2015, Gaseous fire-extinguishing systems - Physical properties and system design - IG-541 extinguishant

AS ISO 14520.2-2006, Gaseous fire-extinguishing systems - Physical properties and system design - CF3I extinguishant

AS ISO 14520.6-2023, Gaseous fire-extinguishing systems - Physical properties and system design - HCFC Blend A extinguishant

AS ISO 14520.9-2019, Gaseous fire-extinguishing systems - Physical properties and system design - HFC 227ea extinguishant

National Fire Protection Association, NFPA 15:2022, Water spray fixed systems for fire protection,

NFPA 16:2019. Installation of foam-water sprinkler and foam-water spray systems.

NFPA 17:2024, Dry chemical extinguishing systems,

NFPA 17A:2021, Wet chemical extinguishing systems,

NFPA 750:2023, Water mist fire protection systems,

NFPA 2001:2022, Clean agent fire extinguishing systems,

NZS 4517:2010, Fire sprinkler systems for houses

NZS 4541:2020, Automatic fire sprinkler systems

Any new, amended or replacement Acts, regulations, standards, codes of practice, guidelines, or authority requirements or conditions affecting this unit standard will take precedence for assessment purposes, pending review of this unit standard.

2 Definitions

Fixed fire protection system refers to engineered sets of components that work together to detect fires, alert occupants, and extinguish fires, and may include fixed or automatic systems, such as those described by the standards listed in the references, used for controlling or putting out fires.

Inspection refers to an organised examination of characteristics of fire protection systems against established standards.

Special hazards fixed fire protection system refers to systems designed and installed to AS 4214:2018, AS 4587:2020, NFPA 15:2022, NFPA 16:2019, NFPA 17:2024, NFPA 17A:2021, NFPA 750:2023, or NFPA 2001:2022 standards. They may include but are not limited to: inert gas; dry chemical; wet chemical; foam, foam-water, water mist; and explosion suppression types of systems.

Systems in this unit standard include – conventional sprinkler system types such as pressurised, floating pressure, pre-action, tail end anti-freeze, dry pipe, alternate wet and dry pipe and deluge systems; and special hazards fixed fire protection systems. Systems documentation refers to the documentation required to be maintained by NZS 4541:2020 and/or other relevant standards listed in the references, including logbook, test reports, equipment details and drawings, specifications, contract agreement, additions and alterations, fire reports, building consents standards, codes of practice, installation instructions, test and commissioning procedures, and test and maintenance records.

Workplace procedures refer to the documented procedures used by the organisation carrying out the work and applicable to the tasks being carried out. They may include but are not limited to – standard operating procedures, site safety procedures, equipment operating procedures, codes of practice, quality assurance procedures, housekeeping standards, charging of time and materials, management of drawings and documentation, procedures to comply with legislative and local body requirements.

3 Assessment information

- a. All activities must comply with relevant legislative and/or regulatory requirements and recognised codes of practice.
- b. All activities must demonstrate safe working practices.
- c. All activities must be completed and reported within agreed timeframes.
- All activities must be done in accordance with systems documentation, plans, NZS 4541:2020, safety guidelines, inspection procedures, and workplace procedures.

NZQA unit standard 27525 version 3
Page 3 of 4

4 Range

For assessment purposes, competence must be demonstrated on at least five different systems including two special hazards system.

Outcomes and performance criteria

Outcome 1

Prepare for inspections for fixed fire protection systems compliance.

Performance criteria

- 1.1 Scope and context for the inspections are established from systems documentation, NZS 4541:2020 and other relevant standards listed in the references.
- 1.2 Systems documentation is assembled.
- 1.3 Site access and timing of the inspections are agreed with site managers or customers.
- 1.4 Site occupational safety and health implications for self and others are identified and control measures put in place.
- 1.5 Inspection plans are prepared.

Outcome 2

Inspect fixed fire protection systems for compliance.

Performance criteria

- 2.1 Systems are inspected to establish compliance.
- 2.2 Customers are advised of non-complying items and arrangements are made for their rectification.
- 2.3 Systems are restored to operational status.
- 2.4 Site personnel are advised of system status and completion of inspection.

Outcome 3

Complete inspection documentation for compliance of fixed fire protection systems.

Performance criteria

- 3.1 Inspection reports and certifications are prepared, sent to stakeholders, and filed.
- 3.2 Details of inspections are entered in the system log.

NZQA unit standard 27525 version 3 Page 4 of 4

3.3 Software versions, where used, and site specific configuration data are included in the report.

Replacement information	This unit standard replaced unit standard 17736.

Planned review date	31 December 2029

Status information and last date for assessment for superseded versions

Process	Version	Date	Last Date for Assessment
Registration	1	21 July 2011	31 December 2017
Review	2	15 October 2015	31 December 2026
Review	3	27 June 2024	N/A

Consent and Moderation Requirements (CMR) reference	0013
---	------

This CMR can be accessed at http://www.nzqa.govt.nz/framework/search/index.do.

Comments on this unit standard

Please contact the Hanga-Aro-Rau Manufacturing, Engineering and Logistics Workforce Development Council qualifications@hangaarorau.nz if you wish to suggest changes to the content of this unit standard.