

<b>Title</b>	<b>Demonstrate knowledge of requirements for ventilation to provide combustion air</b>		
<b>Level</b>	<b>4</b>	<b>Credits</b>	<b>5</b>

<b>Purpose</b>	<p>This unit standard is for people who work in the gasfitting industry.</p> <p>People credited with this unit standard are able to demonstrate knowledge of requirements for ventilation to provide combustion air.</p>
----------------	--

<b>Classification</b>	Plumbing, Gasfitting and Drainlaying > Gasfitting
-----------------------	---

<b>Available grade</b>	Achieved
------------------------	----------

---

### Guidance Information

- 1 References
 

Building Act 2004;  
 Gas Act 1992;  
 Gas (Safety and Measurement) Regulations 2010;  
 Health and Safety at Work Act 2015;  
 Plumbers, Gasfitters, and Drainlayers Act 2006;  
 Plumbers, Gasfitters, and Drainlayers Regulations 2010;  
 The following standards, which are available at <http://www.standards.govt.nz>:  
 AS/NZS 5601.1:2013 *Gas installations*,  
 AS/NZS 5601.2:2013 *Gas installations - Part 2: LP Gas installations in caravans and boats for non-propulsive purposes*;  
 The following clauses, and any related compliance documents, which are available at <https://www.building.govt.nz/>:  
 New Zealand Building Code, Clause E2 External Moisture,  
 New Zealand Building Code Clause G11 Gas as an Energy Source;  
 and all subsequent amendments and replacements.
- 2 For the purposes of outcome 1 ventilation requirements are to be determined to comply with AS/NZS 5601.1:2013, and AS/NZS 5601.2:2013.
- 3 Credit for this unit standard does not entitle the candidate to legally perform certain electrical aspects of this work unless registered or supervised by a registered person under the provisions of the Electricity Act 1992.
- 4 Definition
 

*Free area* – the unobstructed area of a ventilation opening.

---

## Outcomes and performance criteria

### Outcome 1

Demonstrate knowledge of requirements for ventilation to provide combustion air.

### Performance criteria

- 1.1 Identify the burner input relative to room size above which permanent ventilation openings are required.
  - 1.2 Identify the number of openings required for ventilation.
  - 1.3 Describe the locations of the openings required for ventilation.
  - 1.4 Calculate the free area of each ventilation opening.
- 

<b>Planned review date</b>	31 December 2022
----------------------------	------------------

### Status information and last date for assessment for superseded versions

Process	Version	Date	Last Date for Assessment
Registration	1	23 November 2017	N/A

<b>Consent and Moderation Requirements (CMR) reference</b>	0003
--	------

This CMR can be accessed at <http://www.nzqa.govt.nz/framework/search/index.do>.

### Comments on this unit standard

Please contact The Skills Organisation [reviewcomments@skills.org.nz](mailto:reviewcomments@skills.org.nz) if you wish to suggest changes to the content of this unit standard.